



- LEGEND**
- Existing Primary Pole Location
 - Existing Primary Pole Location to be Removed
 - Proposed Primary Pole Location
 - Proposed Primary Self Supporting Pole Location
 - Existing Secondary Pole Location
 - Existing Secondary Pole Location to be Removed
 - Existing Overhead Primary Line
 - Existing Overhead Primary Line to be Removed
 - Proposed Overhead Primary Line
 - Existing Overhead Secondary Line
 - Existing Overhead Secondary Line to be Removed
 - Existing Guy & Anchor Location
 - Proposed Guy & Anchor Location
 - Fence Line
 - Property/Lot Line
 - Acquired PEC Easement Area
 - Existing P.U.E. Line
 - 3Ø 600 AMP Underground Line
 - Proposed 4" Conduit (3 Runs of Conduit)
 - Enclosure Location Proposed
 - Proposed Stub Out
 - ⊕ Meter Location (Existing/Proposed)
 - ⊕ Lightning Arrester Location (Existing/Proposed)
 - ⊕ Fuse Location (Existing/Proposed)
 - ⊕ Equipment to be Removed

GENERAL NOTES:

- 1) PRELIMINARY ROUTE FOR THE ANTHEM NORTH 3Ø EXTENSION (336 AAC)
- 2) DEVELOPER & LAND OWNER OK WITH URD ROUTE THROUGH MR. BETTES PROPERTY. THEY ARE OK WITH INSTALLING GATES TOO
- 3) EASEMENT ACQUISITION NEEDED FOR LOCATIONS 12-13
- 4) ALL EXISTING UG UTILITIES IN THE AREA ARE NOT SHOWN ON CLIP. CALL 811 BEFORE CONSTRUCTION

Approximately 21,736' of OH wire
 Approximately 15,900' of URD wire
 Approximately 27 new pole locations

Disclaimer: This product is for informational purposes only and was not prepared for or suitable for legal, engineering, or surveying purposes. It does not represent an on-the-ground survey and represents only the approximate relative location of property boundaries and facilities. This product is distributed "AS-IS" and without warranties of any kind, either express or implied, including but not limited to warranties of fitness for a particular purpose or use, or as to its performance, accuracy, freedom from error, or as to any results generated through its use.